

Report No. PFE20220501-34 Page 1 of 2
 Sponsor GLOVETEX CO.,LTD.
 Address 11 Moo.5, Soi Klongmadue 17 Setthakij Rd., Donkaidee Krathumban,
 Samutsakorn 74110
 Study Number 65-0126-M001
 Testing Date 29 April 2022
 Expired Date 28 April 2023
 Testing Facility RUEE, Research Unit of Applied Electric Field in Engineering
 Test Procedure PFE Standard Test Method: ASTM F2299-03

Summary: This procedure was performed to evaluate the non-viable particle filtration efficiency of the test article and employed the basic particle filtration method described in ASTM F2299-03. Polystyrene Latex (PSL) were nebulized mono-dispersedly and passed through the test article. The test procedure measures filtration efficiency by comparing between the particle concentration count in the upstream and the downstream ones.


Filtered and dried air is passed through an atomizer to produce an aerosol containing suspended latex spheres. This aerosol is then passed through a charge neutralizer. The aerosol is then mixed and diluted with additional preconditioned air to produce a stable, neutralizer, and dried aerosol of latex spheres.

One-minute particle concentration count were performed, with and without the test article in the system. The filtration efficiency was calculated using the average number of particles penetrating the test article compared to the average of the control values.

Area of test: 17.80 cm²
 Particle Size: PM 2.5
 Face Velocity: 10.6 cm/s
 Environment: 25±3°C and 58±5% relative humidity (RH) for 4 hours
 References: TSI Classifier Model 3082 S/N: 3082001807003,
 TSI CPC Model 3788 S/N: 3788180801,

Average Filtration Efficiency: 98.01 %

Test Article Number	Upstream Counts (particles/cm ³)	Downstream Counts (particles/cm ³)	Filtration Efficiency (%)
1	761,364.00	15,281.00	97.99
2	751,463.00	14,694.00	98.04
3	774,196.00	15,367.00	98.02
4	752,463.00	15,146.00	97.99
5	742,119.00	14,663.00	98.02


 Study Director Assoc. Prof. Dr.Panich Intra

01 - May -2022
 Study Completion Date

Report No. PFE20220501-34

Page 2 of 2

*** End of Report ***

Statement:

1. This report is considered invalid without approved signature;
2. The articles and article information was/were provided by the sponsor who should be responsible for the authenticity with RUEE hasn't verified;
3. The results shown in this report refer(s) only to the articles tested;
4. Without written approval of RUEE, this report can't be reproduced except in their entirety.

Reference Note:

- FACEMASK MICROTEx
- CAREPLUS BLUE LEVEL 2



Study Director Assoc. Prof. Dr.Panich Intra

01 - May -2022

Study Completion Date

"Counterfeiting test report whether it is a whole/part or using a counterfeiting report in any term is an offense under the criminal code"

Tested and Reported by: Research Unit of Applied Electric Field in Engineering (RUEE), 98 Moo 8, Papong, Doi-saket, Chiang Mai, 50220, Thailand

Document Designed by: Wisanapat Ratanachan, Research Unit of Applied Electric Field in Engineering (RUEE)